



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

Blue Ridge Regional Office

www.deq.virginia.gov

Doug W. Domenech
Secretary of Natural Resources

David K. Paylor
Director

Robert J. Weld
Regional Director

Lynchburg Office
7705 Timberlake Road
Lynchburg, Virginia 24502
(434) 582-5120
Fax (434) 582-5125

Roanoke Office
3019 Peters Creek Road
Roanoke, Virginia 24019
(540) 562-6700
Fax (540) 562-6725

FEB 6 2013

**CERTIFIED MAIL
RETURN RECEIPT REQUESTED**

Mr. N. Elwood Holden
Floyd-Floyd County PSA WWTP
PO Box 407
Floyd, VA 24091

Re: **VPDES Permit No. VA0025992**
Floyd-Floyd County PSA WWTP

Dear Mr. Holden:

Your recently reissued permit for Floyd-Floyd County PSA WWTP, effective December 16, 2012, did not include a quantification level for chlorine. This quantification level is needed for chlorine calculations on the Discharge Monitoring Reports. Part I.D.1.a of the permit has been revised to include a quantification level of 0.10 mg/L for chlorine. A copy of this revised permit is enclosed. Please replace these pages in your permit.

If you have questions about the permit, please call Becky L. France at (540) 562-6793.

Sincerely,

Robert J. Weld
Regional Director

Enclosures: Permit No. VA0025992

cc: EPA -- Region III-3WP12